



SI Tower 679-4  
 Yeoksam-Dong, Kangnam-Gu, Seoul, 135-985, Korea  
 Tel : 82-2-2148-8670, Fax : 82-2-2148-8631, E-mail : gckim@gsconst.co.kr

Chief Engineer  
 For Water Networks & Water Works Projects  
 Water Project Department  
 Ministry of Electricity

Date: 11 October 2012  
 Ref. : 091790L-GH/MH-295  
 Page: 1 of 1

**Subject: Contract No. MEW/MC/4333-2010/2011 – Construction and Maintenance of Water Distribution Complex at AZZOUR WDC II**

**Approval of Tank Vendor**

Dear Sir,

Reference to the Contractor letter 091790L-GH/MH-277 dated 30 Sep 2012 and in accordance with Subclause 3.5 "Sub-Contractors" "of the Terms and Conditions of the subject Contract, Contractor submits herewith the qualification documents of the proposed vendor; M/s. Gulf Stainless Steel Factory (Kuwait) for the supply of caustic soda tank and fuel oil tank.

This item is not included in the prequalified vendor list of Section 07; Appendices 16 of the subject Contract.

MEW prompt review and response to the above is anticipated and highly appreciated.

Kind Regards,

*Sangwon Park*

Sang-Won Park  
 Project Manager  
 AZZOUR WDC II Project

4208/WPD/12  
 C.K. 10/10

**ISSUED**  
 2012. 10. 11  
**GS E&C Corp.**  
 CONSTRUCTION AND MAINTENANCE OF  
 WATER DISTRIBUTION COMPLEX AT AZZOUR WDC II



Attachment: Qualification Documents 4 sets

C C: Eng. Maha Yousef Al-hajri - Director of Water Structure Projects Administration  
 Eng. Ali Altammar - Project Engineer

رئيس مهندسي مشاريع المياه  
 وارء رقم : ٤٧٠٣  
 تاريخ : ٢٠١٢/١٠/١١



الذكري الخمسون للجمهورية العربية الكويتية  
50<sup>th</sup> Anniversary of the Independence of the State of Kuwait  
1962 - 2012



دولة الكويت  
وزارة الكهرباء والماء

الإشارة: CEWP-3724-2012

التاريخ: 29-11-2012

M/s. G.S. Engineering & Construction Corporation  
C/O M/s Rank General Trading & Contracting Co.  
P.O Box No: 2416 Safat - 13025  
Fax No: 25458392

الموافق:

Ref: **Contract No: MEW/MC/4333 - 2011/2012**  
**Construction and Maintenance of Azzour WDC - II**

Sub: **Approval of Tank Vendor.**


Dear Sirs,

With reference to your letter ref 091790L-GH/MH-295 dated 11/10/2012 regarding the above mentioned subject matter, we accept your proposed vendor M/s. Gulf Stainless Steel Factory ( Kuwait) for supply of caustic soda tank and fuel oil tank. You are required to submit the detailed drawings of the tanks for approval. Please note that the approval of detailed drawings of fuel oil tank will be required from KNPC and KFBD also.

Best regards,

Yours faithfully,

Chief Engineer  
for Water Networks & Water Works Projects  
Water Projects Department  
Ministry of Electricity & Water



05/11/2012